



Declaration of Conformity

(In accordance with EN 45014)

We,

CPS Products, NV
Krijgsbaan 241
2070 Zwijndrecht
Belgium

Declare under our sole responsibility that the product,

Model LSII, LEAKSEEKER II Refrigerant Leak Detector

To which this declaration relates is in conformity with the following standards or other normative documents:

EN 61326:2006 (Electrical equipment for measurement, control and laboratory use – EMC Requirements)
IEC 61000-4-2:2001 (Electrostatic Discharge Immunity Test)
IEC 61000-4-3:2008 (Radiated , radio-frequency, electromagnetic field immunity test)
European Directive 2011/65/EU (hazardous substances in electrical and electronic equipment)
EN14624:2012 (F-Gas Compliant)

Following the provision of: EMC Directive 2004/108/EC, LVD Directive 2006/95/EC .

In addition, the LS2 has been tested and approved for the detection of tracer gas (95% Nitrogen, 5% Hydrogen), R32, R717, R290 and R600a by the Institut für Luft- und Kältetechnik in Dresden, Germany. The unit detects leaks as small as 3g/a.

The LS2 is safe to use for detecting refrigerants with hydrocarbon components (CFC, HCFC, HFC, HFO, NH3, HC, N2H2) although it's **not intrinsically safe** to use it in a **saturated environment of those hydrocarbon gases**.

The test reports are available upon request.

Signature and Date

Richard Koldewey, VP Engineering CPS Products

Typed Name and Title

Signature and Date

Marc Van Dyck, Managing Director CPS Products Europe, NV

Typed Name and Title

CPS PRODUCTS NV

Krijgsbaan 241, 2070 Zwijndrecht, Belgium

Tel: +32 3 281 3040, Fax: +32 3 281 6583

e-mail: info@cpsproducts.be www.cpsproducts.be